

# VOC Content Test Certificate

Tuesday 22<sup>nd</sup> July 2025

Supplier: Australian Brushware Corporation (20 Council Street, East Howthorn, VIC 3123, AUSTRALIA).

Product Name: MS 3290 Monarch Construction Adhesive Beige

Date Tested: 17<sup>th</sup> July 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>MS 3290 Monarch Construction</b> <b>Adhesive Beige</b>
<b>General Purpose Adhesives and Sealants:</b> <b>50 grams per litre</b>	<b>287 grams per litre as VOC content per material</b>
<i>We hereby certify MS 3290 Monarch Construction Adhesive Beige is above the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant